

Indicators, controllers and monitoring systems for flow, level, pressure and temperature measurement in industrial environments.



**FLUIDWELL**  
Accurate Liquid Management

*Count on us.*

# EU Declaration of Conformity

## Fluidwell C401 Hydrogen Dispenser

Veghel, April 2019

We, Fluidwell BV, declare under our sole responsibility that the C401 indicator is designed and will operate conform the following applicable European Directives and Harmonised Standards, when installed and operated according to the related manual:

<b>EMC Directive</b>	<b>2014/30/EU</b>	EN61000-6-2:2016; EN61000-6-3: 2007 /A1:2011; EN61326-1:2013
<b>RoHS Directive</b>	<b>2011/65/EU</b>	EN 50581:2012
<b>Low Voltage Directive</b>	<b>2014/35/EU</b>	EN61010-1:2010
<b>ATEX Directive</b>	<b>2014/34/EU</b>	EN IEC 60079-0:2018

Increased safety "e": EN 60079-7:2015 + A1:2017

Protective system:  II 3 G Ex ec IIC T4 Gc

<b>Certification</b>	Type Examination Certificate	KIWA 19ATEX0026 X, Issue 1 (not issued as Notified Body)
	Publisher of Certificate:	Kiwa Nederland BV, Unit ExVision, Wilmersdorf 50, 7327 AC, Apeldoorn, the Netherlands.

Last two digits of the year in which the CE marking was affixed: 19.

Fluidwell BV

I. Meij, Manager Technology

Fluidwell BV are ISO9001 certified by DEKRA Certification BV, Meander 1051, 6825 MJ, Arnhem, The Netherlands.



**Fluidwell bv**

P.O. Box 6 • 5460 AA • Veghel  
Voltaweg 23 • 5466 AZ • Veghel  
The Netherlands

Telephone: +31 (0) 413 - 343 786  
Telefax: +31 (0) 413 - 363 443  
Email: [displays@fluidwell.com](mailto:displays@fluidwell.com)  
Internet: [www.fluidwell.com](http://www.fluidwell.com)

Trade Reg. No: 17120985  
VAT No: NL8085.29.699.B.01  
Bank: ING-Bank  
SWIFT Nr / BIC: INGBNL2A

EUR account no: 66.63.96.078  
IBAN: NL73 INGB 0666 3960 78  
USD account no: 02.20.81.771  
IBAN: NL22 INGB 0022 0817 71