

Indicators, controllers and monitoring systems for flow, level, pressure and temperature measurement in industrial environments.



FLUIDWELL
Accurate Liquid Management

Count on us.

EU Declaration of Conformity

Fluidwell D400- and F400-series

Veghel, March 2017

We, Fluidwell BV, declare under our sole responsibility that the D400- and F400-series indicators are designed and will operate conform the following applicable European Directives and Harmonised Standards, when installed and operated according to the related manual:

EMC Directive	2014/30/EU	EN61000-6-2:2005; EN61000-6-3:2007; EN61326-1:2013
RoHS Directive	2011/65/EU	EN 50581:2012
ATEX Directive	2014/34/EU	
	For option –XI, intrinsic safety:	EN60079-0:2009; EN60079-0:2012; EN60079-11:2012;
	Protective system:	Ⓢ II 1 G Ex ia IIC T4 Ga Ⓢ II 1 D Ex ia IIIC T100 °C Da
	For option –XN, non-sparking:	EN60079-0:2009; EN60079-0:2012; EN60079-15:2010; EN60079-31:2009;
	Protective system:	Ⓢ II 3 G Ex nA IIC T4 Gc Ⓢ II 3 D Ex tc IIIC T70 °C Dc
Certification	Certificate intrinsic safety:	KEMA 03ATEX1075 X, Issue 6
	Notified Body 0344:	DEKRA Certification BV, Meander 1051, 6825 MJ, Arnhem, the Netherlands.
	Certificate non-sparking:	DEKRA 13ATEX0115 X, issue 1 (not issued as Notified Body)

Last two digits of the year in which the CE marking was affixed: 03.

Remark: compliance is not affected by standards EN61000-6-3/A1:2011, EN60079-0/A11:2013 and EN60079-31:2014.

Fluidwell B.V.

I. Meij, Manager Technology

Fluidwell BV are ISO9001 certified by DEKRA Certification BV, Meander 1051, 6825 MJ, Arnhem, The Netherlands.



Fluidwell bv
P.O. Box 6 • 5460 AA • Veghel
Voltaweg 23 • 5466 AZ • Veghel
The Netherlands

Telephone: +31 (0) 413 - 343 786
Telefax: +31 (0) 413 - 363 443
Email: displays@fluidwell.com
Internet: www.fluidwell.com

Trade Reg. No: 17120985
VAT No: NL8085.29.699.B.01
Bank: ING-Bank
SWIFT Nr / BIC: INGBNL2A

EUR account no: 66.63.96.078
IBAN: NL73 INGB 0666 3960 78
USD account no: 02.20.81.771
IBAN: NL22 INGB 0022 0817 71