

Indicators, controllers and monitoring systems for flow, level, pressure and temperature measurement in industrial environments.



Count on us.

EU Declaration of Conformity

Fluidwell F1-series indicators

Veghel, January 2019

We, Fluidwell BV, declare under our sole responsibility that the F1-series indicators are designed and will operate conform the following applicable European Directives and Harmonised Standards, when installed and operated according to the related manual:

EMC Directive	2014/30/EU	EN61000-6-2:2016; EN61000-6-3: 2007 /A1:2011; EN61326-1:2013
RoHS Directive	2011/65/EU	EN 50581:2012
Low Voltage Directive	2014/35/EU	
	For options –PM or –OR:	EN61010-1:2010
ATEX Directive	2014/34/EU	EN60079-0:2018
	For option -XI, intrinsically safe:	EN60079-11:2012

Protective system:  II 1 G Ex ia IIB/IIC T4 Ga
 II 1 D Ex ia IIIC T₂₀₀ 100 °C Da

Certification	For Groups II & III, surface installation Notified body 0344:	KEMA 03ATEX1074 X, Issue 6 DEKRA Certification BV, Meander 1051, 6825 MJ, Arnhem, the Netherlands.
----------------------	---	---

Last two digits of the year in which the CE marking was affixed: 03.

Fluidwell BV

I. Meij, Manager Technology

Fluidwell BV are ISO9001 certified by DEKRA Certification BV, Meander 1051, 6825 MJ, Arnhem, The Netherlands.



Fluidwell bv
P.O. Box 6 • 5460 AA • Veghel
Voltaweg 23 • 5466 AZ • Veghel
The Netherlands

Telephone: +31 (0) 413 - 343 786
Telefax: +31 (0) 413 - 363 443
Email: displays@fluidwell.com
Internet: www.fluidwell.com

Trade Reg. No: 17120985
VAT No: NL8085.29.699.B.01
Bank: ING-Bank
SWIFT Nr / BIC: INGBNL2A
EUR account no: 66.63.96.078
IBAN: NL73 INGB 0666 3960 78
USD account no: 02.20.81.771
IBAN: NL22 INGB 0022 0817 71